



Evergreen® VS User Interface
Evergreen VS Motor
Installation Guide

Regal Beloit America, Inc.
 1325 Heil Quaker Blvd.
 LaVergne, TN 37086
 Customer Service: 800 672 6495
 thedealertoolbox.com
 www.regalbeloit.com

FORM
G0075E
Revised
June 2019

⚠ WARNING

WARNING indicates a hazardous situation that, if not avoided, could result in death or serious injury.

- Read and follow all instructions carefully.
- Disconnect and lock out the main power from the unit being serviced before installing the Evergreen VS user interface and motor. It is also a good practice to confirm that the power is disconnected with a voltmeter.
- Do not operate equipment without guards in place.
- Improper installation, adjustment, alteration, service, maintenance, or use could cause explosion, fire, electrical shock, or other conditions. Consult a qualified installer, service agency, or your distributor or branch for information or assistance. The qualified installer or agency must use the supplied or recommended parts when installing or servicing this product.
- After installing the Evergreen VS user interface and motor, it is the responsibility of the installing technician to verify the HVAC system matches the manufacturer’s requirements for proper operation, capacity, efficiency and safety. This includes but is not limited to measuring the airflow and adjusting the Evergreen VS user interface airflow and delay setting in each mode of operation.

⚠ CAUTION

CAUTION indicates a hazardous situation that, if not avoided, could result in minor or moderate injury.

- Periodic inspections should be performed. Failure to perform proper maintenance could result in premature product failure.
- Installation and service of this Evergreen VS user interface and motor should be performed only by trained service technicians familiar with these products.
- This Evergreen VS user interface and motor should be installed in accordance with accepted practices and installation instructions, and in compliance with all national and local codes.

Table of Contents

Page	
2.	Introduction
3.	Identifying Genteq® Model 2.3, Eon®, and 3.0 Motors
4.	Applications
5.	Removal and Installation of the Motor
6-7.	Installation of the Evergreen VS User Interface (UI)
8.	Evergreen VS User Interface (UI) Overview
9.	Sequence of Operation
10.	Commissioning
11.	Airflow and Delay Adjustments
12-13.	Options Menu
14.	Evergreen VS User Interface (UI) Specifications
15.	Evergreen VS Motor Specifications
16.	Technical Support and Warranty



Evergreen® VS User Interface



Evergreen® VS Motor




INTRODUCTION

Evergreen® VS user interface and motor is a two-part system designed to replace Genteq® constant airflow (variable speed) ECM motors including models 2.3, Eon® and 3.0. This includes model 2.3 and 3.0 motors made by Regal or Regal's predecessor companies and bearing brands predating the Genteq brand.

The Evergreen VS motor is a constant airflow (variable speed) motor. It will operate in constant airflow mode when it is receiving digital serial interface (DSI) and constant torque mode when it is receiving pulse width modulation (PWM) communication.


Genteq® model 2.3 or Eon motor replacement (16-pin communication plug)

The Evergreen VS user interface and motor are used together to replace the Genteq model 2.3 or Eon motor.



Genteq® model 3.0 motor replacement (4-pin communication plug)

The Evergreen VS motor is used by itself to replace the Genteq model 3.0 motor.



The Evergreen VS user interface (UI) is compatible with all four Evergreen VS motors. The Evergreen UI is only compatible with Evergreen VS motors. All wires and harnesses required for installation are provided with the user interface.



The Evergreen VS motor is built in four horsepower ratings:

Stock # 6503V	1/3 HP	120/240 VAC	CCW/CW
Stock # 6505V	1/2 HP	120/240 VAC	CCW/CW
Stock # 6507V	3/4 HP	120/240 VAC	CCW/CW
Stock # 6510V	1 HP	120/240 VAC	CCW/CW

All Evergreen VS motors are dual rotation (reversing plug supplied with each motor) and dual voltage (established by the OEM harness).



IDENTIFYING Genteq® MODEL 2.3, EON® and 3.0 MOTORS

(Including motors made by Regal or Regal’s predecessor companies and bearing brands predating the Genteq brand)


- Most Genteq motors are identified with the model name (2.3, Eon and 3.0) on the motor and/or motor control decal.
- If this information is not listed, the motor model number or motor control code can be used to look up the model name.

- o In our free app “The Dealer Toolbelt” (available on Apple and Google Play) you can enter the model number or control code in the “ECM Search” tab to identify the model name of the motor.




Genteq ECM model 2.3 motor identification

- The motor rating decal is located on the side of the motor.




- The motor control decal is located on the side of the control.




Genteq ECM model 3.0 and Eon motor identification

- The motor rating decal is located on the side of the motor.



- The motor control decal is located on the end of the motor control.



APPLICATIONS

Replacing a Genteq® model 2.3 or Eon® motor (16-pin communication plug):

- Applications
 - o Furnace, air handler and package units
 - o Fossil fuel, electric strip heat, A/C, heat pump and geothermal units
 - o Single stage and/or two stage systems only
- Install one (1) Evergreen VS user interface (Stock # 5K010)
- Install one (1) Evergreen VS motor
 - o For proper replacement of Genteq ECM model 2.3 or Eon motors, match the horsepower (HP) and voltage (VAC) ratings of the new Evergreen VS motor to the motor being replaced. It is not necessary for the RPM or the Amperage (FLA) to match.

• Stock # 6503V	1/3 HP	120/240 VAC	CCW/CW
• Stock # 6505V	1/2 HP	120/240 VAC	CCW/CW
• Stock # 6507V	3/4 HP	120/240 VAC	CCW/CW
• Stock # 6510V	1 HP	120/240 VAC	CCW/CW



Genteq ECM model 2.3 motor



Genteq ECM model Eon motor

WARNING! Use the installation instructions in this document to install and set up both the user interface and motor.

Replacing a Genteq model 3.0 motor (4-pin communication plug):

- Applications
 - o Furnace, air handler and package units
 - o Fossil fuel, electric strip heat, A/C, heat pump and geothermal units
 - o Single stage, multi-stage, modulating and communicating HVAC systems
- Install one (1) Evergreen VS motor
 - o For proper replacement of Genteq ECM model 3.0 motors, match the horsepower (HP) and voltage (VAC) ratings of the new Evergreen VS motor to the motor being replaced. It is not necessary for the RPM or the Amperage (FLA) to match.

• Stock # 6503V	1/3 HP	120/240 VAC	CCW/CW
• Stock # 6505V	1/2 HP	120/240 VAC	CCW/CW
• Stock # 6507V	3/4 HP	120/240 VAC	CCW/CW
• Stock # 6510V	1 HP	120/240 VAC	CCW/CW



Genteq ECM model 3.0 motor

WARNING! Use the installation instructions supplied in the box with the motor.

REMOVAL AND INSTALLATION OF THE MOTOR

Remove the old motor

1. Turn off the main line voltage disconnect to the HVAC system.
2. Unplug the 5-pin line voltage plug and the 16-pin communication plug from the ECM model 2.3 or Eon® motor.
3. Remove the old motor from the blower section. Leave the belly band mount connected to the blower section.


Install the new Evergreen® VS motor

1. Determine rotation needed. The Evergreen VS motor is shipped set up for CCW from the lead (plug) end. If CCW is the correct rotation for your job, proceed to step 2. If you need CW rotation, install the rotation plug following the directions below.

- a. Make sure there has been no line voltage connected to the motor for at least 5 minutes.
- b. Remove the two (2) ¼" hex head control bolts.




- c. Disconnect the motor from the motor control.
 - i. Gently pull the motor control away from the motor to expose the motor harness.
 - ii. Disconnect the motor harness from the motor control by depressing the latch on the 3-pin plug.
 - iii. Do not remove the tie strap connecting the motor harness to the X-brace.



Do not remove tie strap

- d. Connect the reversing plug to the motor and the motor control and re-install the motor control and bolts.



NOTE: If the original ECM motor is rated 3/4 or 1 horsepower (HP) and is installed in a 115 VAC application, there may be a power factor correction choke wired in series with the line voltage 5-pin plug. This device should be left in the system as connected by the HVAC OEM.



2. Install the new motor in the existing belly band mount so that the motor plugs are facing down between the 4 and 8 o'clock position as installed in the HVAC system. Also adjust the motor so that the belly band does not block any of the motor's vents.
 - a. If the old motor was built with welded legs or other type of motor mount other than belly band, one of the belly band mounts listed here should be a good match.



Stock # 5K002
48 Frame OEM mount



Stock # 5K003 / 5K004
48 Frame 10" / 11"




Stock # 5K005
48 Frame 13"

INSTALLING THE EVERGREEN® VS USER INTERFACE (UI)

Install the UI so that the screen and buttons are accessible and visible. Orient the UI so that the thermostat wires face down in the HVAC system. There are three holes in each side wing for mounting, and there is two-sided tape on the back. It must also be located to allow the following connections:


- The 16-pin harness from the old motor to the user interface
- The thermostat wires from the user interface to the HVAC system thermostat connections
- The 4-pin harness from the user interface to the new motor




Connecting the user interface (UI) to the new motor and the HVAC system

- Connect the 4-pin plug from the UI to the new motor.
- Connect the 5-pin line voltage plug (disconnected from the old motor) to the new motor.
- Connect the 16-pin communication plug (disconnected from the old motor) to the UI.
- Connect the thermostat wires from the UI to the HVAC system thermostat connections as follows:
 - o Connect the RED wire to the thermostat (R) 24 VAC connection
 - o Connect the BLUE wire to the thermostat (C) 24 VAC Common connection
 - o Connect the GREEN wire to the thermostat (G) Continuous Fan connection
 - o Connect W and Y per the diagrams on the next page related to single stage or two stage systems

NOTE: HVAC manufacturers use different nomenclature (letters and/or numbers) to identify their thermostat terminals (example W, W1, W2). On two stage systems it is important to identify the thermostat terminals used for 1st and 2nd stage.




Failed Genteq® ECM model 2.3 or Eon® motor connections




Installed Evergreen VS user interface and motor connections




Two Stage HVAC Systems connected to a Single Stage Thermostat





Single Stage HVAC Systems with a Single Stage Thermostat



Two Stage HVAC Systems connected to a Two Stage Thermostat



The thermostat wire designations and connections legend are provided on either side of the thermostat wire harness decal.



EVERGREEN® VS USER INTERFACE (UI) OVERVIEW

Thermostat LED – These lights indicate the current thermostat demand. The demand will also appear on the display screen.




System LED – These lights indicate the outputs from the HVAC system control board on the 16-pin plug. The R(PWR) LED indicates the UI is receiving 24VAC from either the thermostat or the 16-pin plug.

- These inputs will help the UI determine when to turn the motor on and when to switch from 1st stage to 2nd stage on two stage systems.





Airflow Buttons – These buttons are used to increase or decrease the airflow (output of the motor in % from 20-100%). The % airflow for the current thermostat demand will appear on the display screen. Press the up button to increase % airflow, the down button to decrease % airflow.

- This information is only present when there is a thermostat demand. Airflow can only be adjusted for the thermostat demand on the screen.




Delay Buttons – These buttons are used to increase or decrease the airflow (output of the motor in % from 20-100%). The % airflow for the current thermostat demand will appear on the display screen. Press the up button to increase % airflow, the down button to decrease % airflow.

- This information is only present when there is a thermostat demand. Airflow can only be adjusted for the thermostat demand on the screen.



Options/Select Button – This button provides advanced options. **See the OPTIONS MENU section on pages 12-13 for details.**



SEQUENCE OF OPERATION

No Demand from the Thermostat = No Operation from the UI



Any thermostat demand at the UI will turn on the corresponding thermostat indicator LED.

The display screen will populate the following information:

- the thermostat demand (example: W1)
- the airflow value directly below (%A/F) example: 60
- the on delay value in seconds directly below (ON) example: 30
- the off delay value in seconds directly below (OFF) example: 90
- the operating state indicator dot (●) to the left of the current operation.



When the dot (●) is to the left of the (ON) delay value, the UI is waiting for the delay to time out.

The operation dot will move to the left of the airflow value, and the UI will turn on the motor at that value when the (ON) delay times out.

- If the (ON) delay value is set to (0), the operation dot will show up to the left of the airflow value when the thermostat demand is initiated, and the UI will turn on the motor.
- If the UI receives a corresponding SYSTEM input, the UI will turn on the motor even if the on delay has not timed out.



When the thermostat demand ends, the operation dot moves to the left of the (OFF) delay value. When the off delay times out, the motor turns off and the display returns to no demand or values displayed.

- If the off delay is set to (0), the UI will turn the motor off when the thermostat demand ends, and the display returns to no demand or values displayed.



2nd Stage Demand Recognition and Operation

- If the UI is receiving a 1st stage thermostat demand, it will transition to 2nd stage operation in the respective demand if one of the following occurs:
 - o The UI receives the 2nd stage thermostat demand
 - o The UI receives the 2nd stage SYSTEM input
 - o The UI (W2) or (Y2) time delay times out
- When the UI receives a 1st stage thermostat demand followed by a 2nd stage demand, it will transition to the 2nd stage demands (%A/F) value and (ON/OFF) delay values on the display screen.
 - o If the motor is operating when the UI receives the 2nd stage demand, the UI will transition the motor operation to the new 2nd stage (%A/F) value.
 - o If the 1st stage on delay has not timed out and the 2nd stage ON delay is (0), the UI will turn the motor on even if the 1st stage on delay has not timed out.
 - o If the 2nd stage on delay is other than (0), and the 1st stage ON delay has not timed out, the motor will turn on when the 1st stage on delay times out.

Continuous Fan Demand and Operation

- If the UI is receiving a thermostat demand on (G), continuous fan, the motor will operate at the (%A/F) value on the display screen with no ON/OFF delay.
 - o If the UI receives any W or Y thermostat demand while it is receiving a G demand, the UI will transition the motor operation to the new (%A/F) value without delay.
 - o When all W and Y thermostat demands end, the UI will transition the motor operation back to the G (%A/F) value without delay.

COMMISSIONING

Operate the system in all modes of operation to confirm the thermostat wiring energizes the proper demand on the user interface and adjust the airflow values and on/off delay values if needed. The values shown on the display screens below, for each thermostat demand, represent the user interface factory default settings.

Confirm the thermostat wiring provides proper demand to the user interface (UI).


Single stage systems

- **A thermostat demand for heat** should turn on the (W) LED thermostat indicator on the UI. The display screen on the UI should display (W2), the airflow value and the on/off delay values.
- **A thermostat demand for cool (or heat pump)** should turn on the (Y) LED thermostat indicator on the UI. The display screen on the UI should display (Y2), the airflow value and the on/off delay values.



Two stage systems

- **A thermostat demand for 1st stage heat** should turn on the (W1) LED thermostat indicator on the UI. The display screen on the UI should display (W1), the airflow value and the on/off delay values.
- **A thermostat demand for 2nd stage heat** should turn on the (W2) LED thermostat indicator on the UI. The display screen on the UI should display (W2), the airflow value and the on/off delay values.
- **A thermostat demand for 1st stage cool (or heat pump)** should turn on the (Y1) LED thermostat indicator on the UI. The display screen on the UI should display (Y1), the airflow value and the on/off delay values.
- **A thermostat demand for 2nd stage cool (or heat pump)** should turn on the (Y2) LED thermostat indicator on the UI. The display screen on the UI should display (Y2), the airflow value and the on/off delay values.



NOTE: The UI is set by default to automatically switch from W1 to W2 airflow and Y1 to Y2 airflow 10 minutes after the thermostat demand for W1 or Y1 is received. This delay setting is to accommodate two stage systems with single stage thermostats.

- For two stage systems with two stage thermostats, changing this delay value to (0) will more accurately match the HVAC system demand to the UI operation of the motor.
- This delay can be adjusted in the OPTIONS menu. See page 12-13 for more details.


Continuous Fan Thermostat Demand

- A thermostat demand for continuous fan should turn on the (G) LED thermostat indicator on the UI. The display screen on the UI should display (G) and the airflow value. There are no on/off delay value options for this demand.



User Interface Lockout

- If the user interface buttons do not function, it may be locked out. The user interface will automatically lock out after 15 minutes of inactivity.
 - o **To unlock the user interface** functions, press both DELAY buttons (ON and OFF) at the same time for 10 seconds. When the indicator changes from "L" to "U," release the DELAY buttons; the user interface is now unlocked.
 - o **Unlocked** is indicated by the "U"; **Locked** is indicated by the "L"
 - o **The flashing dollar sign (\$) next to the U or L is simply a heartbeat, that means the control is operating properly.**




AIRFLOW AND DELAY ADJUSTMENTS

The % AIRFLOW (%A/F) and the ON/OFF delays can only be adjusted when a thermostat demand is present at user interface.

- Single stage systems – Operate the thermostat in heat or cool (heat pump) demand.
- Two stage systems – Operate the thermostat in 2nd stage heat or cool (heat pump) demand.
 - o W1 and Y1 (1st stage) airflow values are locked. They will increase and decrease incrementally with changes to the W2 and Y2 airflow values.
- Continuous fan – Operate the thermostat in continuous fan demand. NOTE: There are no on/off delays.

Airflow Adjustments

Press the AIRFLOW buttons to increase or decrease %A/F value if needed to match measured temperature rise or CFM values to each HVAC system's capacity requirements. The value on the display screen will indicate the change and the motor will immediately increase or decrease output. Up arrow button increases value, down arrow button decreases value.




Delay Adjustments

Press the ON delay button to cycle through the on delay values if needed.

NOTE: On fossil fuel systems, adjusting the ON delay in the W1 and W2 demands from the default of (0) to (30) will give the heat exchanger more time to warm up and provide warmer air temperature at the beginning of each demand.

Press the OFF delay button to cycle through the off delay values if needed.

NOTE: On electric strip heat systems, adjust the OFF delay value as needed to match the off delay of the sequencer to eliminate cool air at the end of each demand.



Defaults

- W1 - %A/F = 60 - On Delay = 0 seconds - Off Delay = 90 seconds
- W2 - %A/F = 85 - On Delay = 0 seconds - Off Delay = 90 seconds
- Y1 - %A/F = 60 - On Delay = 0 seconds - Off Delay = 0 seconds
- Y2 - %A/F = 85 - On Delay = 0 seconds - Off Delay = 0 seconds
- G - %A/F = 40 - On Delay = 0 seconds - Off Delay = 0 seconds
- W1 - W2 Time Delay 10 minutes
- Y1 - Y2 Time Delay 10 minutes

Airflow and Delay Options

Airflow 20-100% (1% increments)

On Delay Values 0, 30, 60, 90, 120 seconds

Off Delay Values 0, 90, 120, 180, 240 seconds

W1 - W2 Time Delay Values 0, 5, 10, 15, 20 minutes

Y1 - Y2 Time Delay Values 0, 5, 10, 15, 20 minutes

NOTE: There is a built in On/Off ramp from each state of operation including Off-On, On-Off and demand to demand. This feature decreases fan noise by allowing the motor to slowly transition from state to state.


OPTIONS MENU

This menu provides options that will enhance the ability of the user interface (UI) to match the operation of the motor to the operation of the HVAC system.

To enter the options menu, press and hold the OPTIONS button for 10 seconds. The UI must be unlocked. The display will give instructions for using the options menu. The OPTIONS menu can be accessed with or without a thermostat demand. Accessing and selecting options in this menu will not affect the airflow or delay values.



In the options menu, the AIRFLOW up/down arrows become the scroll buttons, and the OPTIONS button becomes the SELECT button. You can scroll up or down through the options menu. The menu shown here will follow the selections progression starting with the down arrow.



NOTE: To exit the options menu, you must scroll to (EXIT OPTIONS MENU) and press the SELECT button.

- CAPTURE W2 PWM (L = 000 C = 000)
- CAPTURE Y2 PWM (L = 000 C = 000)



- o For both of these options, the (L) indicates the presence of a PWM signal at the SYSTEM input (16-pin plug). The (C) value will only populate if the SELECT button is pushed. (C) is the captured value the UI will use as a reference. You can capture and recapture the PWM signal by pressing the SELECT button.
- o The purpose of this option is to teach the UI the PWM value associated with the W2 and Y2 HVAC system demands through the SYSTEM input (16-pin plug). The value of teaching the UI this information is to assist the UI in transitioning from 1st stage to 2nd stage airflow. Meaning, if the UI has this value captured, it will automatically transition to 2nd stage airflow when it sees the captured PWM value. This helps the UI transition to 2nd stage airflow at the same time the HVAC system transitions to 2nd stage operation independent of the UI's W2 and Y2 time delays and thermostat inputs.
- o To capture the correct PWM signal, make sure the HVAC system is operating in 2nd Stage heat to capture the W2 PWM or 2nd stage cool (heat pump) to capture the Y2 PWM.
- o Press the AIRFLOW down arrow to scroll between these two options or to the next.

- TIMED W2 = 10
- TIMED Y2 = 10



- o To change these values, press the SELECT button once to scroll through each value option. The value options include 0, 5, 10, 15 and 20 minutes. The value on the screen is the value the UI will save. Then use the AIRFLOW arrows to scroll to the next screen in the OPTIONS menu.
- o Both of these options are factory set to 10 minutes specifically to support two stage systems that use single stage thermostats. With single stage thermostats, the UI will not receive the 2nd stage thermostat demand. The UI will automatically transition from 1st stage airflow to 2nd stage airflow if it sees the appropriate value on the W2 or Y2 SYSTEM input (16-pin plug). The timed W2 and Y2 values simply ensures that if the HVAC system transitions to 2nd stage, and the SYSTEM input does not detect this, that the UI will automatically transition to 2nd stage airflow after the selected time.
- o For two stage systems with two stage thermostats, the HVAC system will provide the UI with the 2nd stage thermostat demand. Therefore, these settings should be set to (0).

- UNLOCK W1
- UNLOCK Y1



- o These options are only needed if the airflow in 1st stage heat or cool (heat pump) need to be adjusted independently of the 2nd stage. These values are locked by default at a specific % value of W2 and Y2 to make it easier to set the airflow in two stage systems.
- o To unlock these values, press the SELECT button once. The display will change to:


- UNLOCK W1 = done
- UNLOCK Y1 = done




- o This function can only be returned to locked by resetting all of the UI values to factory default in the RESTORE DEFAULTS option in this menu.
- o Press the AIRFLOW down arrow to scroll between these two options or to the next.

OPTIONS MENU (Continued)

- Motor Output Type = RPM
 - o This feature is only used to support the RPM or airflow indicator used on some HVAC system controls. This feature should be left at the default setting (Type=RPM) unless technical support advises otherwise.
- DIAGNOSTICS – Provides a go/no go test on the motor.
 - o To enter the diagnostics screen, press the SELECT button once. From the next screen you can do a run test of the motor. If for any reason the motor does not operate, this test provides a go/no go test to prove the motor is operational.
 - Press the SELECT button once to initiate the test. A dot (●) will appear to the left of the word run (●RUN). While the dot is on the screen, the motor should operate.
 - The dot will disappear after 20 seconds, and the motor should then turn off. You can exit the DIAGNOSTICS screen at any time by pressing the up/down AIRFLOW arrows. This will return you to the options menu.
 - o The information on this screen is simply a place for us to store the software version of the UI and other internal data.
 - o Press the AIRFLOW down arrow to scroll to the next option at any time.
- RESTORE DEFAULTS – This option resets all values to the factory defaults including airflow and delay values, and all values in the OPTIONS menu.
 - o To restore the UI, press the SELECT button.
 - The display will change to (--DEFAULTS-- wait)
 - Then automatically change to (Genteq)
 - Then automatically exit out of the OPTIONS menu
- EXIT OPTIONS MENU – This is the only screen you can exit the options menu from unless you use the RESTORE DEFAULTS option. From this screen press the SELECT button to exit the options menu.



Motor Output
Type = RPM



DIAGNOSTICS




Fbb008 M0 P0 000
RUN MTR 000




Fbb008 M0 P0 000
-RUN MTR 020




Fbb008 M0 P0 000
RUN MTR 000




RESTORE DEFAULTS




--DEFAULTS--
wait...



Genteq



U\$ %A/F ON/OFF



EXIT OPTION MENU

EVERGREEN® VS USER INTERFACE (UI) SPECIFICATIONS

Dimensions: 5.5" x 3.35" x 1.25"

Voltage Rating




- Thermostat inputs are rated for 18-30 VAC

Ambient Ratings

- Operating Temp 0°C to +50°C (32°F to 122°F)
- Storage Temp -20°C to 70°C (-4°F to 158°F)

Lead Lengths

- Thermostat leads – 36"
- Motor harness – 36"



EVERGREEN® VS MOTOR SPECIFICATIONS

Voltage: 120/240 (Operating range 90-132 VAC/180-264 VAC)

Horsepower: 1/3, 1/2, 3/4, 1

Communication Input: PWM OR DSI (Auto switch)

Rotation: CCW or CW by reversing plug (factory set to CCW)

- As viewed from lead end
- Communicated rotation with DSI communication

Bearing: Permanently lubricated ball bearing

Ambient Ratings:

- Powered, not operating: -20° to 65°C (non-icing conditions)
- Operating (1/3, 1/2, and 3/4 HP): -20° to 55°C (non-icing conditions)
- Operating (1 HP): -20° to 45°C (non-icing conditions)

Enclosure: Open Air Over (OAO), NEMA® 48-Frame (5.6" diameter)

Shaft: Single, 1/2" diameter, 5" length, 4.5" single flat

Mounting: Horizontal or vertical shaft-down (VSD), belly band

UL and CSA recognized component

Encapsulated electronics


Electronic overload protection

6kV surge protection



STOCK #	HP	VOLTAGE	FLA	ROTATION	RPM	FRAME
6503V	1/3	120/240	5.0/2.8	CCW/CW	1050	NEMA 48
6505V	1/2	120/240	7.7/4.3	CCW/CW	1050	NEMA 48
6507V	3/4	120/240	10.1/6.1	CCW/CW	1050	NEMA 48
6510V	1	120/240	12.8/7.4	CCW/CW	1050	NEMA 48

HP	DIM B
1/3	5.71
1/2	6.21
3/4	6.96
1	7.71



TECHNICAL SUPPORT

Phone support: Between the hours of 8am-5pm (CST) Monday-Friday at 866-503-8566 Option 3.

Scan this code with your smart phone or go to www.EvergreenVS-motors.com.



Terms & Conditions of Sale & Limited Warranty

Sales of the products described in this Installation Manual are subject to the "Regal Beloit Terms and Conditions of Sale" current at the time of sale. They are accessible on RegalBeloit.com – <https://www.regalbeloit.com> (click "Regal Terms and Conditions of Sale").

The full Limited Warranty, including the scope and period, remedies, exclusions and disclaimers, is described in Section 10 "Limited Warranty" of the Regal Terms and Conditions of Sale and applies except as described below:

Section 10(a)(1) is replaced with the following: Seller warrants that the Products shall be delivered free from defects in material, workmanship and title. This warranty shall expire twenty-four (24) months from first use of the Product or thirty (30) months from date of shipment of the Product, whichever occurs first.

NEMA is believed to be the trademark and/or trade name of National Electrical Manufacturers Association and is not owned or controlled by Regal Beloit Corporation.

Regal, Eon, Evergreen and Genteq are trademarks of Regal Beloit Corporation or one of its affiliated companies.
©2019 Regal Beloit Corporation, All Rights Reserved. MCIM19001E • Form# G0075E

